

Commercialization of Greywater Recycling

Environmental Management Division

Consultant Tim Wong 18th March 2019





Introduction

June 1963 - May 1964

Severe Water Rationing - 4 hours of supply every 4 days





Introduction

• To prepare for the declining rainfall due to climate change and the rapidly increasing water demand in the Pearl River Delta region, the Government has formulated a Total Water Management (TWM) strategy.

降雨減6成 料明春續大旱

油荒之後、廣東省可能又要范討另一 端荒──「水荒」。廣東省市の北支局市 、廣東省市0月10年均有量。僅是近年同期 平均總量的4成、省內4大江河点成的水流量 也明顯減少、直到明年春天、省內的水流量 候港尽量緊張。 ■本知2名 候子桌

有珠三角港商表示,今年的供水情况比上 年更差,氟論是生活用水還是工業用水,都要 另想辦法解決。

應要省小交员表示,省內本市10月的降消 量值得31毫米,比多年交同期的平均量減少了 6级;當中,主要供應減三角及看涉用水的東 江泥道,10月仍降雨量只有16.1毫米,比去年 同期的57.8毫米錫減715多,當問指計,今年 冬季亞明牛春季的水溜酒形勢,不容裝載。

東江水庫存量 減三分一

事重上,應更用量明顯減少,區內江河 水克量也相關明顯降低。據了解,目前全省 22座大型水面的蓄水量為127度之刀水,而東 江水原只有40億立方米,比方年而關處少續 20億立方米,水利專家預計,由於11月全省 降間重約需貨少,水資源供邀將時損必整。 学生现在公,面出的标志。伊迪加尔加尔教育 教育家院长,目外大桥交已通过选择文称。在这期东水 家馆影繁新城。水力东设备"自龙出来杂水, 都选责汇念。"明晰是未有之穷诚道。《全律标 词。 一条理定之指出,与我防乐大家乐,部分转 当局准确只有花则源及影响高方点走速到"前 就方面、必定工编最近山面"(图点人到山上致 如次定于新社自是并,所以工能改有偷的资源进 行,公案面面。

港商外市買水 廢水循環

另外,亦有港做還擇在工廠天台加建水 缸,起仍有水供應時先行儲存更多用水,亦有 港做索性直接從範疇或引發買水,總來繼標 指,還一單水的費用服幾千元人民幣, 些治方面,一些泡燃則採取,「溶水循環 目,約從120%10日本,總於四為山灣建百名

戶而方面,一些港灣則將執,何,僅不備項內 用」的辦法來節約用水,雖然要為比異建百多 萬元入民幣一個的環保過還水處,用來過還方 水,但能夠節者用水之餘,許暫應政府要求來 環保,不失是信辦法。



Water is a precious instruet resource. The Government has formulated the Total Water Management Strategy for ensuring sustimulate use of water resources. We appeal for the support and active participation of all in the Community for the successful implementation of the measures in the Strategy to prepare us for possible acute climate changes or low rainfall. It is of paramount importance to engage our young generation, so that the effort will be well sustained. TUNTE Total Water Management in Hong Kong



Mr. MA Lee Tak, JP Director of Water Supples The Government of the Heng Kong Special Administrative Region Development Blueso







Total Water Management

- Water Demand Management
 - To enhance public education on water conservation
 - To promote use of water saving devices
 - To enhance water leak control
 - To extend use of seawater for toilet flushing
- Water Supply Management
 - To strengthen protection of water resources
 - To actively consider water reclamation (including reuse of greywater and rainwater harvesting)
 - To develop the option of seawater desalination



Greywater provides a constant source of water for reuse



Greywater

- Domestic wastewater excluding wastewater from toilet or urinal (blackwater - feces, urine and flushing water)
- Wastewater from
 - Showers, baths, washing basins
 - Clothes washing/laundry
 - Kitchens



Greywater Mining





Potential Applications – Unrestricted Non-potable Reuse



Toilet Flushing (for the remaining 20% areas without seawater flushing)



Irrigation for Plants & Green Roof



General Cleaning (Car Washing & Street Cleaning)



Water Features



Makeup Water for Cooling Tower



Fire Fighting



HKPC's patented greywater recycling system









Treatment Process

Submerged Aerated Filter (SAF)

- Media are installed for the attached growth of microorganisms
- Can hold a large amount of biomass and have a much higher treatment efficiency

Micro-filtration (MF)

- Hollow fibre membranes of pore size 0.1-0.4 μm to separate clean water from the SAF effluent
- No sedimentation tank, so reducing the space required
- The treated water is crystal-clear, free of germs and odour
- Membrane can be automatically backwashed







Submerged Aerated Filter (SAF)

Packing Media

- PVC 60° cross-fluted media with large specific surface area up to 240 m²/m³
- Large voidage of >97%

Process Microbiology

- Micro-organisms grow and develop on the surface of media (biofilm)
- Decomposition of organic takes place in biofilm
- As the biofilm grows thicker, it will slough off from the media
- MLSS is much lower than that of activated sludge (~100 mg/L)







Microfiltration (MF)

- Typical fibre diameter ~1.0 mm
- Pore size 0.1–0.4 μ m (smaller than bacteria)
- Water flow is outside-in
- Cross-flow filtration to suppress membrane fouling
- Auto-backwash and air scouring for membrane cleaning











Treatment Process

Disinfection

 To maintain a residual chlorine level to prevent re-growth of bacteria in pipes, a certain amount of chlorine disinfectant is dosed

The whole treatment process has been patented

- HK Short Term Patent No.: HK1095980



Case references in Hong Kong and Mainland



70 m³/day City University of Hong Kong (First installation in HK, 2009)



1 m³/day Office building in HK



12 m³/day URA Redevelopment



30 m³/day Collaborated with 深圳建築科學研究院 To build a demo plant in Shanghai



1 m³/day Office building in HK



50 m³/day Public Estate in Tuen Mun (First installation for housing estate in HK)



Greywater Recycling System in CityU

Start Operation:

Designed Treatment Capacity:

September 2009

7 m³/hr

Aim: Reduction of the use of city water for irrigation so as to achieve water conservation

Sources:

i) Washing basins in about 60 toilets

ii) Condensate from central air handling unit (AHU)







Location of the Plant



HKPC®

Plant Layout



Plant room:

- 15 m x 4.7 m
 (58 m² effective floor area)
 - separated into 4 compartments

BACKWASH PUMP

• 2.3 m headroom







System Outlook



Reception/Biological Tanks



Membrane Filtration Unit



Parameter	Water Quality	HK Technical Specifications		
pH	6.4–8.2	6 ~9		
Colour (Hazen unit)	<5	≤20		
Odour (Odour unit)		≤100		
Turbidity (NTU)	<0.1–0.3	≤5		
Conductivity (µS/cm)	67–410			
Biochemical oxygen demand (BOD ₅)/(mg/L)	<3–8	≤10		
Chemical oxygen demand (mg/L)	<5-29			
Ammonia nitrogen (mg/L)	<0.05-0.2	≤1		
Anionic Surfactant (mg/L)	0.1–0.3			
Suspended solids (mg/L)	<5	<u>≤</u> 5		
<i>E. Coli</i> (cfu/100 mL)	<1	<1		
Total residual chlorine (mg/L)	System outlet 1.0–1.8	System outlet≥1.0 , End of pipe≥0.2		







Performance

Membrane Product Water



Membrane Feed Water







Reclaimed Water Quality

Turbidity of Reclaimed Water





Ammonia Nitrogen of Reclaimed Water



HKPC°

Colour of Reclaimed Water



HKPC°

E.Coli of Reclaimed Water





Running Cost

Source	Cost (HK\$ per m ³)
Electricity cost	~1.2
Chemical cost	~0.2
Consumables and membrane replacement	~0.45
Reclaimed water from greywater recycling (Tuen Mun Project)	~ HK\$ 1.85

Money saving from greywater recycling = HK\$ (4.58+2.92–1.85)

(with effect from 1st April 2017)

= HK\$ 5.65 /m³ reclaimed water



Reference costs from local installations

Project	Capacity (m ³ /day)	Capital Cost (HK\$)	Recurrent Cost (HK\$/month)
City University of Hong Kong	70	\$0.9 Million	\$3 k
EMSD Headquarters	30	\$1 Million	-
TKO Area 86	440	\$6.7 Million	\$20 k



Major Constraints of Greywater Recycling in HK

- Space constraint
 - Conventional/off-the-self systems would not be compact and flexible enough to fit into the congested space
- Operation requirement
 - Need simple and forgiving operation to minimize operator attendance
- Reclaimed water quality for hygiene concerns
 - Need sophisticated treatment processes to provide safe reclaimed water complying to Technical Specifications
- Economic viability
 - Need reduced capital investment to encourage greywater recycling
 - Need to minimize operating cost to achieve net money saving



Greywater Recycling System in CityU

CityU system has demonstrated that:

- Very little space required
 - System is very compact and flexible, and can be fit into a 58 m² basement plant room
- Minimal operation & maintenance
 - Consistently superior reclaimed water quality with little operator attendance for over 5 years
- Relatively low capital investment
 - System cost : less than HK\$1 million
- Operation cost
 - ~HK\$1.5/m³ resulting in a net money saving of HK\$6/m³



Greywater Recycling System in Tuen Mun Start Operation: November 2018 Designed Treatment Capacity: 5 m3/hr

Aim: Reduction of the use of city water for irrigation so as to achieve water conservation

Sources:

Shower trays, water basins of tenants' toilets, floor drain of tenants and washing machine







Greywater Recycling System in Tuen Mun





Parameter	Water Quality	HK Technical Specifications		
рН	6.9–7.1	6 ~9		
Colour (Hazen unit)	<5	≤20		
Odour (Odour unit)		≤100		
Turbidity (NTU)	<0.4-0.5	≤5		
Biochemical oxygen demand (BOD5)/(mg/L)	<5	<u><</u> 10		
Ammonia nitrogen (mg/L)	<0.05-0.2	≤1		
Suspended solids (mg/L)	<5	<u><</u> 5		
<i>E. Coli</i> (cfu/100 mL)	<1	<u><</u> 1		
Total residual chlorine (mg/L)	System outlet 1.01.8	System outlet≥1.0 , End of pipe≥0.2		
Threshold Odour Number	<1	<u>≤</u> 100		
Legionella Bacteria Count	<10	<u>≤</u> 10 (cfu/ml)		
Heterotrophic Colony Count	<1	\leq 100,000 (cfu/ml)		





Standard Packaged Systems

System Model	Operating Hours	Reclaimed Water		Reclaimed Water for			Reception Tank	Product Tank	Space
		Hourly Flow Rate	Daily Flow Rate	Irrigation ¹	Toilet Flushing ²	No. of User	Required	Required	Required
	hr/day	m³/hr	m³/day	m²	No. of users		m³	m³	m²
GW-01	- 5~10	0.1	1	200	27	Up to 27	0.2	0.2	~1.2
GW-05		0.5	5	1,000	130	Up to 130	2	2	~25
GW-10		1	10	2,000	130~260	130~260	3	3	~28
GW-20		2	20	4,000	260~530	260~530	5	5	~38
GW-50		5	50	10,000	530~1,330	530~1,330	5	5	~50
GW-100		10	100	20,000	1,330-2,660	1,330-2,660	5	5	~75

1 5L/m²/d

Reference: Project Profile of "Rainwater and Greywater Recycling in Tseung Kwan O (TKO) Area 86 Property Development"

2 37.5 L/head/day

Reference: Baseline WC Water Use in BEAM Plus for Existing/New Buildings Version 1.2



Layout Sample



HKPC®

Layout Sample



ELEVATION

BIOLOGICAL

TREATMENT TANK

<u>_</u>__

BUFFER TANK JB ES ES

ACCESS

Capacity: 1 m³ /hr



Major Potential Users in Hong Kong

- School and university campuses
- Youth campsites and sports centres
- Residential and commercial buildings (esp. green buildings)
- Hotels
- Shopping centres





Potential Market in Mainland China

- Starred hotels and resorts
- Large shopping centres (including hypermarkets and department stores)
- Factories and worker dormitories
- Small residential communities
- Commercial buildings in urban areas





